

I/62561/2023

OFFICE OF THE MEDICAL OFFICER OF HEALTH
ROOM NO. 1002, 10TH FLOOR
NEW DELHI MUNICIPAL COUNCIL
PALIKA KENDRA, NEW DELHI

No D/147/smo

Date : 01/05/2023

To,

The Principal,
Carmel Convent School,
Chanakyapuri,
New Delhi 110021.

Sub: Health and Sanitation Certificate of Carmel Convent School,
Chanakyapuri.

Madam,

With reference to your application dated 21.03.2023 regarding Sanitation Certificate for the Carmel Convent School, Chanakyapuri, New Delhi 110021.


The School Building was inspected on dated 27.04.2023 by the Area Sanitary Inspector (Health) and found fit from health/sanitation point of view.

Signed by Ramesh Kumar


Date: 29-04-2023 15:50:24

(DR. RAMESH KUMAR)

MEDICAL OFFICER OF HEALTH



Principal
Carmel Convent School
New Delhi-110021



**WATER QUALITY MONITORING UNIT
AMRIT BHAWAN, VINAY MARG, CHANAKYAPURI
QUALITY CONTROL & TECHNICAL AUDIT CELL
NEW DELHI MUNICIPAL COUNCIL
ISO 9001-2015 CERTIFIED**

1. Name & Address of Sender:- *Principal, Carmel Convent School, Chanakyapuri*
 2. Date of Receiving/Collection:- *21/3/23*
 3. Sample No.:- *3007-3008*
 4. Sealed Sample (Yes/No):-

SAMPLE NOT COLLECTED
BY UNIT STAFF

**DRINKING WATER TESTING REPORT
TEST-RESULTS**

Sr. No.	Location, Date & Time of Sample Collection Site	Colour (Pt-Co Scale)	Taste & Odour	Turbidity (NTU)	pH	Total Hardness (as CaCO ₃) (Mg/L)	TDS (Mg/L)	Iron (as Fe) (Mg/L)	Chloride (as Cl) (Mg/L)	Residual free Chlorine (Mg/L)	Coliform org. MPN / (100 ML)	E.Coli MPN/ 100 ML
1.	<i>Boys Building Ground floor</i>	<i><5</i>	<i>Agreeable</i>	<i>0.2</i>	<i>7.6</i>	<i>12</i>	<i>26</i>	<i>0.03</i>	<i>08</i>	<i>NIL</i>	<i>NIL</i>	<i>—</i>
2.	<i>Boys Building First floor</i>	<i><5</i>	<i>Agreeable</i>	<i>0.1</i>	<i>7.3</i>	<i>06</i>	<i>14</i>	<i>0.02</i>	<i>04</i>	<i>NIL</i>	<i>NIL</i>	<i>—</i>
3.												
4.												
5.												
BIS: 10500 2012	Acceptable Limits	05 max	Agreeable	1 max.	6.5 To 8.5	200 max.	500 max.	0.3 max.	250 max.	0.2 min.	NIL	NIL
	Permissible Limits (in the absence of alternate source.)	15	Agreeable	5	No relaxation	600	2000	No relaxation	1000	1	NIL	NIL

Remarks:- With respect to above tests, all the above water samples ~~except~~ Sr. No. *3007-3008* can/cannot be considered fit for drinking purposes. However minimum residual free chlorine 0.2 Mg/L should be done to avoid contamination.

23/03/23
Chemist/Lab. Technician

23/3/23
Lab. Technician/Asstt.

- Note:-**
- 1) water samples will be destroyed after testing unless otherwise specified by party.
 - 2) If the sample is not collected by our WQM staff, the sender/party will be responsible for any wrong, incomplete or misleading information given by him.
 - 3) This test report is not valid for any legal proceeding.

Amr Mani Gaur
Principal
Carmel Convent School
New Delhi-110021