



GOVERNMENT OF WEST BENGAL,
DIRECTORATE OF PUBLIC HEALTH ENGINEERING,
OFFICE OF THE EXECUTIVE ENGINEER,
SILIGURI WATER SUPPLY DIVISION,
DISTRICT LABORATORY AT FULBARI,
SILIGURI


PHYSICAL AND CHEMICAL TEST REPORTS :


Date Of Collection	19.02.2020
Date Of Analysis	19.02.2020
Date Of Reporting	19.02.2020


*The tests done with the Sample as deposited by the Party.

SL. NO.	Parameters	Acceptable Limit	Cause of Rejection	RESULT	
				Place	Delhi Public School, Chhobavita, Canal Road, Fulbari
				Source	R.O. Filtered
				Sender	Headmistress, Delhi Public School
1.	Turbidity (NTU)	1	10		0.85
2.	pH	7.0 to 8.5	<6.5 or >9.2		6.89
3.	TDS(ppm)	500	2000		71
4.	Colour(Hz)	5	25		0.29
5.	Iron (mg/l)	0.1	1.0		0.09
6.	Res. Chlorine (mg/l)	0.2	>1.0		0
7.	Fluoride (mg/l)	1.0	1.5		0.59
8.	Total Hardness(mg/l)	300	600		38
9.	Total Alkalinity(mg/l)	200	600		34
10.	Chloride (mg/l)	200	600		16.99
11.	Nitrate (mg/l)	45	45		4.78
12.	Copper (mg/l)	0.05	0.5		0.03

Physical & Chemical Test Charge @ Rs. 900.00/ Sample


Chemist/Bacteriologist,
District Laboratory,
Fulbari, W.T.P.


Junior Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.



Assistant Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.


Memo No. 2117/1 /SD: Date: Siliguri, the 24/02/2020


Copy forwarded for information and necessary action to:-

1. The Headmistress, Delhi Public School.
2. Office Copy.

Feb-16

For Delhi Public School

Prin. V.P.


Executive Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.

For Delhi Public School

Principal




GOVERNMENT OF WEST BENGAL,
DIRECTORATE OF PUBLIC HEALTH ENGINEERING,
OFFICE OF THE EXECUTIVE ENGINEER,
SILIGURI WATER SUPPLY DIVISION,
DISTRICT LABORATORY AT FULBARI,
SILIGURI


BACTERIOLOGICAL ANALYSIS :


Date Of Collection	19.02.2020
Time Of Collection	11.05 AM
Date Of Analysis	19.02.2020 TO 20.02.2020
Date Of Reporting	20.02.2020

Sl No.	Bacteriological Parameters	Acceptable Limit	RESULT	
			Place	Delhi Public School, Chhobavita, Canal Road, Fulbari
			Source	R.O. Filtered
			Sender	Headmistress, Delhi Public School
1.	Total Coliform Present/Absent MPN (per 100ml)	Absent		ABSENT
2.	Faecal Coliform Present/Absent MPN (per 100ml)	Absent		ABSENT
3.	WATER BACTERIOLOGICALLY SAFE/UNSAFE	--		SAFE

*The tests done with the Sample as deposited by the Party.
Bacteriological Test Charge @ Rs. 500.00/ Sample


Chemist/Bacteriologist,
District Laboratory,
Fulbari, W.T.P.


Junior Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.


Assistant Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.


Memo No. 2118/1 /SD: Dated, Siliguri, the 24/02/2020

Copy forwarded for information and necessary action to:-

1. The Headmistress, Delhi Public School.
2. Office Copy.

For Delhi Public School


Pro VC


Executive Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.

Feb-06

For Delhi Public School


Principal

Government of West Bengal
Office of The Chief Medical Officer of Health
Public Health Branch
1st Floor Administrative Building District Hospital, Jalpaiguri

Memo No. 654

Date: 27-02-2020

To
The Principal
Delhi Public School, Fulbari
Chhobavita, Canal Road Fulbari P.O. Bhaktinagar
Jalpaiguri-734015

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Name of the School: - Delhi Public School, Fulbari

Curriculum: - CBSE

Location: - Chhobavita, Canal Road Fulbari P.O. Bhaktinagar, Jalpaiguri-734015

Descriptions of the School: - There are all total 49 rooms including 36 Classrooms, 9 Labs, 2 Wellness room/Clinic, 1 Staff room and 1 Library. There are 24 Washrooms with separate provisions for male and female. All the rooms and also all the washrooms are well maintained w.r.t. the sanitary conditions. There is one mini canteen within the school building for the students which is not for commercial purpose and well maintained w.r.t. the sanitary conditions. There is also one Cafeteria outside the building within the campus used for commercial purpose which is running by a third party agency. All the norms w.r.t. Food Safety has been informed to the agency.

Descriptions of Surrounding: - The areas surrounding the school building are well maintained w.r.t. the sanitary conditions. There is drain along the boundary wall which is connected to a high drain outside. The garbage generated is regularly cleared and dumped in a separate area within the campus far away from the school building. Both the drain and garbage are treated regularly.

Source of water: - The source of water is through submersible pump through which the water lifted to the overhead tank and after purifications through RO filter and chlorination supply to the building for difference purpose.


Cleanliness Activities: - The School premises and the building are being cleaned regularly and maintained through third party agency. Occasionally, the students are being involved in cleanliness activities as a part of their social educations.


Social Activities: - The School undergoes different social activities for examples – Think Green Plantation Programme on February 2019, Mahananda Cleanliness on February 2019, Conservation of Water on June 2019 etc.

Therefore, this is to certify that an inspection was done by the team headed by Dy. CMOH-II, Jalpaiguri from the Department of Health and Family Welfare on 27.02.2020 and found that the Delhi Public School, Fulbari, Chhobavita, Canal Road Fulbari P.O. Bhaktinagar, Jalpaiguri 734015 has safe drinking facilities for the students and members of staff of the Institution and is maintaining the hygienic sanitary condition in the school building and the campus as per the norms prescribed by the central/state/U.T. Govt.

The above certificate valid for a period of one year.

For Delhi Public School


Pro V.C.


Dy. Chief Medical Officer of Health – II
Jalpaiguri

For Delhi Public School


Principal

Dy. Chief Medical Officer of Health-II
Jalpaiguri