

CERTIFICATE REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.- 1102

Date-07/10/2024

It is certificate that an inspection team headed by Mrs. Sunita K (Assistant Engineer) District Water Tensting Laboratory Jagdalpur, District-Bastar (C.G.) inspected *Vidya Jyoti Senior Secondary School Danteshwari Ward-20 Geedam Road Jagdalpur (C.G.)* on 04.10.2024 and found that *Vidya Jyoti Senior Secondary School Danteshwari Ward-20 Geedam Road Jagdalpur (C.G.)* test parameter (NABL) - Turbidity, Colour, Odour, pH, Total Alkalinity, Total Dissolved Solid, Chloride, Total Hardness, Calcium, Magnesium, Fluoride & parameter (Non-NABL) - Spec. Conductivity, Iron has safe drinking water facilities for student an members of staff is maintaining hygienic sanitation condition in the school and the campus as per the norms prescribed by the Central/State/Union Terriory Government.

Sunita K

Sunita K

Assistant Engineer

PHE G.W.R. Sub Division

Jagdalpur (C.G)

To

Principal

Vidya Jyoti Senior Secondary School

Jagdalpur District-Bastar (C.G.)



TC-13342

District Water Testing Laboratory Public Health Engineering Division Jagdalpur, Dist.-Bastar (C.G.)

Near Collectorate Road, Pin Code – 494001

E-mail -: phelabjdp@gmail.com

Test Report**Group- Drinking Water**

Report No. - DL/PHED/JDP/418	ULR-FC133422400000418F		Sampled by – Mr. Uday	
Sender's Name and Address :- Principal Vidya Jyoti Senior Secondary School Jagdalpur.	Sender's letter No. :	Q	Sender's Letter Date :	01-10-2024
	DL Receipt No. :	319	DL Receipt Date :	03-10-2024
	Date of Analysis started :	04-10-2024	Date of Analysis Completed :	04-10-2024

Sample Details

Sr.no	Block	Sample ID	Village	Location / Source
1	Jagdalpur	319/2241/Oct24	Danteshwari Ward-20	Geedam Road/Vidya Jyoti Senior Secondary School

Details of parameters, their test method, units and specification as per IS 3025/APHA

Results

Sr. No.	Characteristics	Unit of Measurement	Test Method	1					
1	Turbidity	NTU	IS 3025 Part No.-10 (2023)	1.3					
2	Colour	Hazen	IS 3025 Part No.-04 (2021)	5					
3	Odour		IS 3025 Part No.-05 (2018)	Agreenable					
4	pH	pH Scale	IS 3025 Part No.-11 (2022)	7.06					
5	Total Alkalinity as CaCO ₃	mg/L	IS 3025 Part No.-23 (2023)	30.29					
6	Total Dissolved Solid at 180°C±2°C	mg/L	IS 3025 Part No.-16 (2023)	60					
7	Chloride as Cl ⁻	mg/L	IS 3025 Part No.-32 (2019)	10.34					
8	Total Hardness as CaCO ₃	mg/L	IS 3025 Part No.-21 (2019)	45.31					
9	Calcium as Ca ²⁺	mg/L	IS 3025 Part No.-40 (2023)	15.00					
10	Magnesium as Mg ²⁺	mg/L	APHA 24 th 3500-Mg-B (2023)	1.91					
11	Fluoride as F ⁻	mg/L	APHA 24 th 4500-F- C (2023)	0.17					

- The report should not be produced partly or full without approval of signatory authority of legal purpose.
- It is recommended that acceptable limit is to be implemented. Value in excess of those mentioned under "Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 7. above which the sources will have to be rejected.
- The results refer only to tested samples and parameters.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
- Samples will be stored for a period of 10 days from date of issue of report.

Remark:- 1. Results apply to the sample as received.**2. Sampling not done by Laboratory's Staff.**

Laboratory issue no. 418/Lab/Date:- 07-10-2024

Hemant Kashyap

Chemist/Authorized Signatory (NABL)

Format No.- DL/PHED/JDP/4.1

District Water Testing Laboratory
Public Health Engineering Division Jagdalpur, Dist.-Bastar (C.G.)

Near Collectorate Road, Pin Code – 494001

E-mail -: phelabjdp@gmail.com

Test Report

Group- Drinking Water

Report No. - DL/PHED/JDP/418		Sender's letter No. : Q		Sampled by – Mr. Uday	
Sender's Name and Address :- Principal Vidya Jyoti Senior Secondary School Jagdalpur.		DL Receipt No. : 319		Sender's Letter Date : 01-10-2024	
		Date of Analysis started : 04-10-2024		DL Receipt Date : 03-10-2024	
		Date of Analysis Completed : 04-10-2024			
Sample Details					
Sr. No	Block	Sample ID	Village	Location / Source	
1	Jagdalpur	319/2241/Oct24	Danteshwari Ward-20	Geedam Road/Vidya Jyoti Senior Secondary School	
Details of parameters; their test method, units and specification as per IS 3025/APHA				Results	
Sr. No.	Characteristics	Unit of Measurement	Test Method	1	
1	Spec. Conductivity	μS/cm	IS 3025 Part No.-14	100	
2	Nitrate as NO ₃ (Screening Method)	mg/L	APHA 24 th 4500-NO ₃ -B	-	
3	Iron as Fe	mg/L	APHA 24 th 3500-Fe-B	0.2	
4	Manganese as Mn ⁺⁺	mg/L	APHA 24 th 3500-Mn-B	-	
5	Sulphate as SO ₄ ²⁻	mg/L	IS 3025 Part No.-24	-	
6	Residual Chlorine	mg/L	IS 3025 Part No.-26	-	
7	E. Coli	CFU/ 100ml	APHA 24 th 9222 B	-	
8	Total Coliform Bacteria	CFU/ 100ml	APHA 24 th 9222 B	-	

1. The report should not be produced partly or full without approval of signatory authority of legal purpose.
2. It is recommended that acceptable limit is to be implemented. Value in excess of those mentioned under "Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 7, above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters.
4. This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
5. Samples will be stored for a period of 10 days from date of issue of report.

Remark:- 1. Results apply to the sample as received.

2. Sampling not done by Laboratory's Staff.

Laboratory issue no. 418/Lab/Date:- 07-10-2024


Hemant Kashyap
Chemist

NABL Report Limit

Details of parameters, their test method, units and specification as per IS 3025/APHA				As Per IS - 10500-2012 (Second Revision) For Drinking Water	
Sr. No.	Characteristics	Unit of Measurement	Test method	Acceptable Limit	Permissible Limit in the absence of alternate source
1	Turbidity	NTU	IS 3025 Part No.-10 (2023)	1	5
2	Colour	Hazen	IS 3025 Part No.-04 (2021)	5-15	No Relaxation
3	Odour		IS 3025 Part No.-05 (2018)	Agreeable	Agreeable
4	pH	pH Scale	IS 3025 Part No.-11 (2022)	6.5-8.5	No Relaxation
5	Total Alkalinity as CaCO ₃	mg/L	IS 3025 Part No.-23 (2023)	200	600
6	Total Dissolved Solid at 180°C±2°C	mg/L	IS 3025 Part No.-16 (2023)	500	2000
7	Chloride as Cl ⁻	mg/L	IS 3025 Part No.-32 (2019)	250	1000
8	Total Hardness as CaCO ₃	mg/L	IS 3025 Part No.-21 (2019)	200	600
9	Calcium as Ca ²⁺	mg/L	IS 3025 Part No.-40 (2023)	75	200
10	Magnesium as Mg ²⁺	mg/L	APHA 24 th 3500-Mg-B (2023)	30	100
11	Fluoride as F ⁻	mg/L	APHA 24 th 4500-F- C (2023)	1.0	1.5

Non - NABL Report Limit

Details of parameters, their test method, units and specification as per IS 3025/APHA				As Per IS - 10500-2012 (Second Revision) For Drinking Water	
Sr. No.	Characteristics	Unit of Measurement	Test method	Acceptable Limit	Permissible Limit in the absence of alternate source
✓ 1	Spec. Conductivity	μS/cm	IS 3025 Part No.-14	500	2000
2	Nitrate as NO ₃ ⁻ (Screening Method)	mg/L	APHA 24 th 4500-NO ₃ - B	45	No Relaxation
✓ 3	Iron as Fe	mg/L	APHA 24 th 3500- Fe- B	1.0	No Relaxation
4	Manganese as Mn ⁺	mg/L	APHA 24 th 3500-Mn-B	0.1	0.3
5	Sulphate as SO ₄ ²⁻	mg/L	IS 3025 Part No.-24	200	400
6	Residual Chlorine	mg/L	IS 3025 Part No.-26	0.2	1
7	E. Coli	CFU/ 100ml	APHA 24 th 9222 B	Nil	Nil
✓ 8	Total Coliform Bacteria	CFU/ 100ml	APHA 24 th 9222 B	Nil	Nil